

**Emergency Lighting – Weekly Tests**

**Location:** \_\_\_\_\_ **Month:** \_\_\_\_\_ / 201\_

**Weekly Test Instructions**

- Check previous faults and actions recorded in the fire register have received attention.
  - Check that every lamp in a maintained system is lighting as required.
  - Check that every LED status indicators are illuminated and showing healthy condition / status.
  - Check that the main control / indicating panel of each central battery system or static inverter system indicates normal operation.
  - Check that the main control / indicating panel of each engine driven generator plant indicates normal operation.
  - Record any faults and subsequent actions taken and record in the fire register.
- NOTE** – Automatic Test Systems (ATS): Monthly short duration test results shall be recorded below.

Date	Initial	Location	Faults Found	Action Taken