

## Fire Hydrants – Weekly Tests

**Location:** \_\_\_\_\_ **Month:** \_\_\_\_\_ / 201\_

### Weekly Test Instructions

- Ensure there are no obstructions impeding access to the hydrant.
- The following tests refer to above ground hydrants only.
  - (1) Check that the indicator plate is in the correct position.
  - (2) Check that the isolation valves are locked in an open position.
- Record any faults and subsequent actions taken.

Date	Initial	Location	Faults Found	Action Taken