

Fixed Gaseous Extinguishing Systems – Weekly Tests

Location: _____ **Month:** _____ / 201_

Weekly Test Instructions

- Visually inspect and check that there have been no changes to the integrity of the enclosure for changes which might reduce the efficiency of the system.
- Check that there is no obvious damage to pipework and that all operating controls and components are properly set and undamaged.
- If fitted, check that pressure gauges and weighing devices are reading correctly.
- Record any faults and subsequent actions taken and record in the fire register.

Date	Initial	Location	Faults Found	Action Taken