

Fire Doors Six-Monthly Tests

Location: _____ **Date:** _____ / 201_

Six-Monthly Testing Instructions

- Check that the heat-activated seals and smoke seals are undamaged.
- Ensure the door leaves are not damaged or deformed.
- Inspect the integrity of the system including hanging devices, securing devices and all other mechanisms are operating correctly.
- Record any faults and subsequent actions taken.

<i>Date</i>	<i>Initial</i>	<i>Faults Found</i>	<i>Action Taken</i>

SCA-FR.F.14.01 Fire Doors

Note: This form allows biannual checks to be recorded by the user. Once the proposed testing month is arranged, place this form in the corresponding monthly tab. Once the test is complete, move this form to the next due test date tab within that calendar year.