## Fire Extinguishers - Monthly

Location:	Month:	/ 201_
-----------	--------	--------

## **Monthly Testing Instructions**

- Check they are in designated location and signed accordingly.
- Ensure clear visibility and unobstructed accessibility.
- Ensure anti-tamper seals / tabs remain intact and unbroken.
- Check that the pressure gauge is within operational range.
- Examine for damage or defects such as clogged nozzle, corrosion or leakage, damaged hose or mounting.
- Monitor inspection date labels and keep within test dates.
- Record any faults and subsequent actions taken.

**Note:** Examine fire blankets for evidence of wear by unfolding the blanket and inspecting for defects / damage.

Date	Initial	Faults Found	Action Taken
SCA_ER E 11 O	1 Fire Extinauis	hers	
	T FIFE EXHIBITION		

Note: Monthly forms should be moved to the next months tab when checks have been completed for the current month.